

**WILLISTOWN TOWNSHIP
CHESTER COUNTY, PENNSYLVANIA**

ORDINANCE NO. ____ of 2024

**AN ORDINANCE AMENDING CHAPTER 105 OF THE CODE OF
ORDINANCES OF WILLISTOWN TOWNSHIP, GOVERNING SPECIFIC
DISCHARGE PROHIBITIONS INTO WASTEWATER COLLECTION
SYSTEMS**

BE IT AND IT IS HEREBY ENACTED by the Board of Supervisors of Willistown Township, Chester County, as follows:

Section 1. The Code of the Township of Willistown, Chapter 105, Section 32.B (5) is hereby amended to read as follows:

Wastes that exceed any of the following concentrations in a discharge to the process stream of the treatment plant from a connected user as sewage or Tier I waste or from a nonconnected discharge (through a licensed waste hauler) as a Tier I waste, as a daily composite sample or grab sample:

Tier I Limits:

Arsenic (total)	0.04	mg/L
Cadmium (total)	0.09	mg/L
Chromium (total)	4.00	mg/L
Copper (total)	1.00	mg/L
Cyanide (total)	0.26	mg/L
Lead (total)	0.10	mg/L
Mercury (total)	0.005	mg/L
Molybdenum (total)	0.50	mg/L
Nickel (total)	0.90	mg/L
Selenium (total)	0.50	mg/L
Silver (total)	0.08	mg/L
Zinc (total)	1.00	mg/L

Section 2. The Code of the Township of Willistown, Chapter 105, Section 32.B (6) is hereby amended to read as follows:

Wastes that exceed any of the following concentrations in a discharge to the septage discharge station of the treatment plant from a nonconnected discharge (through a licensed waste hauler) as a Tier II waste in a grab sample or daily composite sample:

Tier II Limits:

Arsenic (total)	2.50	mg/L
Cadmium (total)	0.50	mg/L
Chromium (total)	21.00	mg/L
Copper (total)	22.00	mg/L

Cyanide (total)	0.26	mg/L
Lead (total)	18.00	mg/L
Mercury (total)	0.04	mg/L
Molybdenum (total)	5.00	mg/L
Nickel (total)	5.00	mg/L
Selenium (total)	4.00	mg/L
Silver (total)	5.00	mg/L
Zinc (total)	95.00	mg/L

Section 3. This Ordinance shall be effective five (5) days from the date of enactment.

ENACTED and **ORDAINED** this _____ day of _____, 2024.

**BOARD OF SUPERVISORS
WILLISTOWN TOWNSHIP**

Robert T. Lange, Chair

William R. Shoemaker, Vice Chair

Molly H.B. Perrin, Member

ATTEST:

Shanna Lodge, Manager